

**MAHARASHTRA INDUSTRIAL DEVELOPMENT CORPORATION**  
(A Government of Maharashtra Undertaking)

**HEAD OFFICE**

"Udyog Sarthi", Mahakali Caves Road,  
Andheri (E), Mumbai - 400 093  
Tele: (022) 26870052/54/27/73 Fax: (022)  
26871587

**PRINCIPAL OFFICE:** 4, 4 (A), 12<sup>th</sup> Floor, World Trade Centre,  
Complex-1, Cuffe Parade, Mumbai-400 005  
Tele: (022) 22151451/52/53 Fax: (022) 22188203



No. MIDC/Fire/P-725322  
Date: 13/07/2026.

M/s. Institute for Rural Development  
And Social Service.  
Plot No.P-44, MIDC Addl.,  
Jalgaon I,II Indl. Area,  
Dist. Jalgaon.

**Sub.:** Grant of "Final Fire Safety Approval" for your proposed construction of Educational Building on Plot No. P-44, MIDC Addl., Jalgaon Indl.Area, Dist.-Jalgaon.

**Ref.:** 1. This office Prov. NOC No. MIDC/Fire/I/125552/2025 dtd.29/07/2025.  
2. Your online application vides No. **SWC/45/25/20260706/1145578**

Dear Sir,

With reference to the above, a representative of this office visited your Industrial building on 11/07/2026 situated at the above-mentioned address for inspection of firefighting arrangements provided by you. Since the firefighting arrangements provided by you were found in satisfactory working conditions; this office is issuing a "Final Fire Safety Approval" for your proposed construction of Industrial building as per Provisional No-Objection certificate. The plot area is 3,602 Sq. Mtrs. The existing Built Up area is 1764.83 and proposed built up area is 277.27 Sq. Mtrs. The details of the proposed construction are as under;

**Building: A (Proposed Shed):**

| Sr. No. | Floor Name      | Proposed FSI Area | Stair | Height |
|---------|-----------------|-------------------|-------|--------|
| 01      | Second Floor... | 277.172           | 18.99 | 11.57  |
|         | Grand Total.    | 277.172           | 18.99 |        |

- The Occupant Load in above buildings should not exceed in any case as prescribed in Table-3 of National Building Code 2016, Part IV.

**Following Statutory Provisions under Maharashtra Fire Prevention and Life Safety Measures Act, 2006:**

- Under Section (3)** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (hereinafter referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2005 and as amended from time to time failing which it shall be treated as a violation of the said Act.

**Principal**

Gurukulam Global School  
P.No.44,Behind Jinda Bhavan  
M.I.D.C.Jalgaon

2. It is presumed that you have completed the work adhering to the provisions under Section (3) of the said Act.
3. Under sub-section (3) of Section (3), it is responsibility of the owner or the Occupier as the case maybe, shall furnish to the Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of Jan & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in Sub Section (1).
4. Under sub section (4) of Section (3), no person shall tamper with, alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other person to do so.
5. You are hereby informed that the proposed building or part of building or floor or part of floor shall not be occupied without obtaining "Occupation certificate" from concerned Special Planning Authority of MIDC failing which you will be fully responsible for consequences, if any.
6. If the building or part of building is Sub-leased, sold to some other company then the prospective buyer/sub-leased must obtain "No-Objection Certificate" from this office before occupying his building/ floors. You are hereby informed to incorporate suitable clause to that effect in sub-lease agreement or agreement for sale.

The Fire Extinguishers and other fire protection systems installed by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the said system is not maintained, retrenched, this N.O.C. will stand cancelled without any notice & you will be fully responsible to loss of life or property, if any, which may please be noted.

| Particulars                    | Total Amount | Advance "Fire Protection Fund fees" paid by M/s. SAPREM PULSES AND SPICES. Vide receipt no GL26561286 Dt 10/02/2026 | Balance "Fire & Emergency fees" needs to be recovered by SPA |
|--------------------------------|--------------|---------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------|
| (i)                            | (ii)         | (iii)                                                                                                               | (iv)                                                         |
| "Fire & Emergency service fee" | Rs.30,109.00 | Rs. 00.00                                                                                                           | Rs.30,109.00                                                 |
| Total                          | Rs.30,109.00 | Rs. 00.00                                                                                                           | Rs.30,109.00                                                 |

The conditions mentioned in the "Provisional No-Objection Certificate" will remain unchanged. The undersigned reserves right to amend/suggest any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of the activity or transfer or subletting of plot or future expansion No-Objection Certificate from this office is essential.**

Thanking you.


Yours faithfully,

SUNIL  
TULSHIRAM  
INGAWALE

Digitally signed by SUNIL  
TULSHIRAM INGAWALE  
Date: 2026.07.13  
16:54:37 +05'30'

(S.T. Ingawale)  
Divisional Fire Officer  
MIDC, Nashik Region.

Copyfwc's to the MIDC, Sub Division Jalgaon (SPA) for your information.

  
Principal  
Gurukulam Global School  
No.44, Behind Jinda Bhavan  
M.I.D.C. Jalgaon