



MAHARASHTRA STATE PUBLIC HEALTH SERVICES



DISTRICT PUBLIC HEALTH LABORATORY JALGAON

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER(As per BIS Specification 10500:2012)

dphljal@gmail.com

Phone: (0257)2229221

Name & Address Of Sender.	:- Gurukulam Global School, P-44, Additional M.D.C., Jalgaon.				
Sender's Letter No.& Date	:- 30-7-2026				
Laboratory Reference No.	:- 5003				
Date of Collection	:- 30-7-2026				
Date of Arrival at Laboratory	:- ———				
Date of Commencing Examination:-	:- ———				

Sr. No.	Particular of Water Samples	Result of Analysis Most Probable Number Per 100 ml.			Remark
		Coliforms	Thermotolerant Coliforms	E.coli	
1.	Ro water sample	00	—	—	fit for drinking

Remark: Unfit water samples can be used, Only after proper treatment, chlorination and retesting bacteriologically to ascertain its/their fitness for drinking purposes.

Note :- Above water sample was not collected by this laboratory.

Govt.Receipt No.	3220704	Dt	30/7/26	Rs.	340/-
------------------	---------	----	---------	-----	-------

Report Outward No. :- 2435

Date :- 05-08-2026

(Signature)
Principal
Gurukulam Global School
P.No.44, Behind Jinda Bazar
M.D.C.

(Signature)
District Scientific Officer
District Public Health Laboratory
Jalgaon - 390001